# GOVERNMENT OF INDIA
# POWER
# LOK SABHA

UNSTARRED QUESTION NO:86
ANSWERED ON:20.11.2000
PENDING POWER PROJECTS OF GUJARAT
DILEEP SANGHANI

**Will the Minister of POWER be pleased to state:**

(a) whether the Government have received any proposal from Gujarat for setting up Jamnagar Thermal Power Plant, Phase-I for clearance;

(b) if so, the action taken by the Government in this regard;

(c) if not, the reasons for delay in this regard;

(d) whether the Government has returned seventeen other power projects to the State Government for re-submission of these projects as per the modified policy of the Government in this regard;

(e) if so, whether the Government have received the revised proposals of these projects from the State Government;

(f) if so, the action taken by the Government in this regard;
(g) if not, the reasons for delay in clearance of these projects; and
(h) the time by which these projects are likely to be cleared?

## Answer

THE MINISTER OF STATE IN THE MINISTRY OF POWER ( SHRIMATI JAYAWANTI MEHTA )

(a) : Yes, Sir. The Government received a proposal from Gujarat forsetting up Jamnagar Thermal Power Plant (2x250 MW) in the private sector by M/s. Reliance Power Ltd. for techno-economic clearance.

(b) : The project has been cleared techno-economically by Central Electricity Authority (CEA) on 24.5.1999.

(c) : Construction on the project has not yet started as financial closure of the project is yet to be achieved.

(d) to (g) : The details of proposals received for setting up power projects in Gujarat for which Detailed Project Reports (DPRs) have been returned by Central Electricity Authority, along with reasons for returning the same are given in Annexure.

(h) : The projects will be taken up for clearance once the Detailed Project Reports complete with all necessary inputs/clearances are furnished by the utilities.

ANNEXURE

ANNEXE REFERRED TO IN REPLY TO LOK SABHA UNSTARRED QUESTION NO. 86 TO BE ANSWERED ON 20.11.200
PARTS (d) TO (g) REGARDING PENDING POWER PROJECTS OF GUJARAT

Details of proposals for setting up power projects in Gujarat for which Detailed Project Reports (DPRs) were returned by Central Electricity Authority for resubmission.

| NAME OF PROJECT | CAPACITY (MW) | DATE OF RETURN / REASON FOR RETURN |
|---|---|---|
| Pipavav CCGT (GPCL) | 615 | Returned on 10.10.96 for want of GOG clearance for use of 100% Naphtha, fuel linkage of MOP&NG, fixing of executing agency in private sector |
| Gas based TPS at Mahuva | 2x210 | Returned on 7/80 Fuel availability was not tied up. |
| Utran GTCC St.II | 135 | Returned on 5/92 due to non-availability of gas from Gandhar fields. |
| Sinor GTCC | 1230 | Returned on 6/92 due to non-availability of gas. |
| Simultaneous cycle Gas based plant at Balol | 6x5.5 | Returned on 2/88 |

Kalol 6x5.5
Ankleshwsar 6x5.5

Co-operative sector GTCC TPS
for National Dairy
Development Board at
Samarakha 236 CEA intimated DOP on 6.11.89 that they are not in favour of this scheme and desired that NDDB may take bulk power from GEB.
Pipavav CCGT St.II 615 Gas envisaged from Tapti fields is not likely to be available in near future. Gas for St.I proposal also not yet been confirmed. GEB has also resources constraints. GEB was informed on 11.2.92 accordingly.
North Gujarat CCGT 300 Returned on 8/93 due to non-availability of gas.
Gandhinagar CCGT 200 In 8/91 GEB was requested to submit revised report with 1 GT+1 ST configuration for low cost per KW and better efficiency.
GEB intimated in 10/91 that revised report will be sent after envirnoment clearance is received.
Narmada St.I 2x500 Returned in 7/92 as coal linkage and transportation could not be tied up. Scheme has also been rejected by MOEF.
Sikka St. III 2x210 Returned in 8/92 as certain linkages such as coal linkage, E&F clearance etc. were not tied up.
Scheme has also been rejected by MOEF.
Wanakbori GTCC 600 Returned in 10/92 as gas is not likely to be available from HBJ pipeline in the near future.
Gujarat Coastal (GEB)
at Amreli 2x500 Returned in 2/96 as Fuel, Environment, Civil Aviation, Trans. System, could not be tied up.
Kharsalia Lignite
Fired Plant 120 Returned on 28.2.96 due to non tie up of certain inputs.
Ghoga Lignite based 2x120 Returned on 12.7.96 as the project is proposed in private sector and the company is yet to be finalised.
Coastal TPS(GPCL) 2x500 Proposal for IPC returned on 17.9.96 due to nonfinalisation of private agency which are executing the project and MOU route is not open.
Other pending inputs : Section 29(2), MOEF clearance, coal linkage, transmission system.
Sikka TPS Extn.U-3 &4 2x250 Returned on 7.9.99. Pending inputs are Land availability, water availability, MOEF clearance, Fuel Linkage, SPCB clearance, Compliance of Sec.29(2) &(3), Firm Completed Cost, Tentative Financial Package, NOC of NAA, Fuel transport arrangement.
Dhuvaran Gas PP 100 Returned on 2.5.2000, Pending inputs are Water Availability, Fuel Linkage, NOC of SPCB, compliance of Sec. 29(2) & (3), NOC of NAA, power evacuation system, State Govt. consent u/s 18A
Surat Lignite Power (T) Project
Extn. Ph.II 2x125 Returned on 23.10.2000. Pending inputs/ clearances are land availability, fuel linkage, water availability (S&C), NOC of SPCB. NOC of State Envirnoment Department, NOC of NAA.